

Scottish Borders Council

Regulatory Services – Consultation reply

Planning Ref	17/00257/FUL
Uniform Ref	17/00499/PLANCO
Proposal	Replacement windows and installation of chimney flue
Address	5 High Street Innerleithen Scottish Borders EH44 6HA
Date	17/3/17
Amenity and Pollution Officer	David A. Brown
Contaminated Land Officer	Reviewed – no comments

Amenity and Pollution

Assessment of Application

Air quality

Nuisance

This Application includes a proposal to install a flue.

The indicated flue height is insufficient to allow fumes to disperse properly and will affect the amenity of other occupiers.

Recommendation

Object.