

From:Kirk, Cameron
Sent:Mon, 21 Nov 2022 09:09:12 +0000
To:DCConsultees
Subject:FW: Community Council Consultation for application 22/01416/PPP

From: alison campbell <secretary.coldstreamcc@gmail.com>
Sent: 21 November 2022 09:08
To: Kirk, Cameron <Cameron.Kirk@scotborders.gov.uk>
Subject: Re: Community Council Consultation for application 22/01416/PPP

CAUTION: External Email

CDCC was supportive of this application

On Wed, 26 Oct 2022 at 10:50, <cameron.kirk@scotborders.gov.uk> wrote:

Please see attached document

***** This email and any files transmitted with it are privileged, confidential and subject to copyright. Any unauthorised use or disclosure of any part of this email is prohibited. If you are not the intended recipient please inform the sender immediately; you should then delete the email and remove any copies from your system. The views or opinions expressed in this communication may not necessarily be those of Scottish Borders Council. Please be advised that Scottish Borders Council's incoming and outgoing email is subject to regular monitoring and any email may require to be disclosed by the Council under the provisions of the Freedom of Information (Scotland) Act 2002 .

Friday, 28 October 2022



Local Planner
Development Management
Scottish Borders Council
Newtown St. Boswells
TD6 0SA

Development Operations
The Bridge
Buchanan Gate Business Park
Cumbernauld Road
Stepps
Glasgow
G33 6FB

Development Operations
Freephone Number - 0800 3890379
E-Mail - DevelopmentOperations@scottishwater.co.uk
www.scottishwater.co.uk



Dear Customer,

1 Kelso Road, Coldstream, TD12 4LG
Planning Ref: 22/01416/PPP
Our Ref: DSCAS-0075374-3TH
Proposal: Erection of 2no dwellinghouses

Please quote our reference in all future correspondence

Audit of Proposal

Scottish Water has no objection to this planning application; however, the applicant should be aware that this does not confirm that the proposed development can currently be serviced. Please read the following carefully as there may be further action required. Scottish Water would advise the following:

Water Capacity Assessment

Scottish Water has carried out a Capacity review and we can confirm the following:

- ▶ There is currently sufficient capacity in the Rawburn Water Treatment Works to service your development. However, please note that further investigations may be required to be carried out once a formal application has been submitted to us.

Waste Water Capacity Assessment

- ▶ There is currently sufficient capacity for a foul only connection in the Coldstream Waste Water Treatment works to service your development. However, please note that further investigations may be required to be carried out once a formal application has been submitted to us.

Please Note

- ▶ The applicant should be aware that we are unable to reserve capacity at our water and/or waste water treatment works for their proposed development. Once a formal connection application is submitted to Scottish Water after full planning permission has been granted, we will review the availability of capacity at that time and advise the applicant accordingly.

Surface Water

For reasons of sustainability and to protect our customers from potential future sewer flooding, Scottish Water will not accept any surface water connections into our combined sewer system.

There may be limited exceptional circumstances where we would allow such a connection for brownfield sites only, however this will require significant justification from the customer taking account of various factors including legal, physical, and technical challenges.

In order to avoid costs and delays where a surface water discharge to our combined sewer system is anticipated, the developer should contact Scottish Water at the earliest opportunity with strong evidence to support the intended drainage plan prior to making a connection request. We will assess this evidence in a robust manner and provide a decision that reflects the best option from environmental and customer perspectives.

General notes:

- ▶ Scottish Water asset plans can be obtained from our appointed asset plan providers:
 - ▶ Site Investigation Services (UK) Ltd
 - ▶ Tel: 0333 123 1223
 - ▶ Email: sw@sisplan.co.uk
 - ▶ www.sisplan.co.uk
- ▶ Scottish Water's current minimum level of service for water pressure is 1.0 bar or 10m head at the customer's boundary internal outlet. Any property which cannot be adequately serviced from the available pressure may require private pumping arrangements to be installed, subject to compliance with Water Byelaws. If the developer wishes to enquire about Scottish Water's procedure for checking the water pressure in the area, then they should write to the Customer Connections department at the above address.
- ▶ If the connection to the public sewer and/or water main requires to be laid through land out-with public ownership, the developer must provide evidence of formal approval from the affected landowner(s) by way of a deed of servitude.
- ▶ Scottish Water may only vest new water or waste water infrastructure which is to be laid through land out with public ownership where a Deed of Servitude has been obtained in our favour by the developer.

- ▶ The developer should also be aware that Scottish Water requires land title to the area of land where a pumping station and/or SUDS proposed to vest in Scottish Water is constructed.
 - ▶ Please find information on how to submit application to Scottish Water at [our Customer Portal](#).
-

Next Steps:

▶ All Proposed Developments

All proposed developments require to submit a Pre-Development Enquiry (PDE) Form to be submitted directly to Scottish Water via [our Customer Portal](#) prior to any formal Technical Application being submitted. This will allow us to fully appraise the proposals.

Where it is confirmed through the PDE process that mitigation works are necessary to support a development, the cost of these works is to be met by the developer, which Scottish Water can contribute towards through Reasonable Cost Contribution regulations.

▶ Non Domestic/Commercial Property:

Since the introduction of the Water Services (Scotland) Act 2005 in April 2008 the water industry in Scotland has opened to market competition for non-domestic customers. All Non-domestic Household customers now require a Licensed Provider to act on their behalf for new water and waste water connections. Further details can be obtained at www.scotlandontap.gov.uk

▶ Trade Effluent Discharge from Non-Domestic Property:

- ▶ Certain discharges from non-domestic premises may constitute a trade effluent in terms of the Sewerage (Scotland) Act 1968. Trade effluent arises from activities including; manufacturing, production and engineering; vehicle, plant and equipment washing, waste and leachate management. It covers both large and small premises, including activities such as car washing and laundrettes. Activities not covered include hotels, caravan sites or restaurants.
- ▶ If you are in any doubt as to whether the discharge from your premises is likely to be trade effluent, please contact us on 0800 778 0778 or email TEQ@scottishwater.co.uk using the subject "Is this Trade Effluent?". Discharges that are deemed to be trade effluent need to apply separately for permission to discharge to the sewerage system. The forms and application guidance notes can be found [here](#).
- ▶ Trade effluent must never be discharged into surface water drainage systems as these are solely for draining rainfall run off.
- ▶ For food services establishments, Scottish Water recommends a suitably sized grease trap is fitted within the food preparation areas, so the

development complies with Standard 3.7 a) of the Building Standards Technical Handbook and for best management and housekeeping practices to be followed which prevent food waste, fat oil and grease from being disposed into sinks and drains.

- ▶ The Waste (Scotland) Regulations which require all non-rural food businesses, producing more than 50kg of food waste per week, to segregate that waste for separate collection. The regulations also ban the use of food waste disposal units that dispose of food waste to the public sewer. Further information can be found at www.resourceefficientscotland.com

I trust the above is acceptable however if you require any further information regarding this matter please contact me on **0800 389 0379** or via the e-mail address below or at planningconsultations@scottishwater.co.uk.

Yours sincerely,

Angela Allison

Development Services Analyst

PlanningConsultations@scottishwater.co.uk

Scottish Water Disclaimer:

"It is important to note that the information on any such plan provided on Scottish Water's infrastructure, is for indicative purposes only and its accuracy cannot be relied upon. When the exact location and the nature of the infrastructure on the plan is a material requirement then you should undertake an appropriate site investigation to confirm its actual position in the ground and to determine if it is suitable for its intended purpose. By using the plan you agree that Scottish Water will not be liable for any loss, damage or costs caused by relying upon it or from carrying out any such site investigation."

**CONSULTATION RESPONSE TO
PLANNING OR RELATED APPLICATION**

Comments provided by	Officer Name and Post:		Contact e-mail/number:	
Roads Planning Service	Craig Johnston Roads Planning Technician		Craig.johnston@scotborders.gov.uk 01835 826856	
Date of reply	07/11/2022		Consultee reference:	
Planning Application Reference	22/01416/PPP		Case Officer: Cameron Kirk	
Applicant	Mr Andrew Douglas-Home			
Agent	Camerons Strachan Yuill Architects			
Proposed Development	Erection of 2no dwellinghouses			
Site Location	Land South Of 1 Kelso Road Coldstream Scottish Borders			
<i>The following observations represent the comments of the consultee on the submitted application as they relate to the area of expertise of that consultee. A decision on the application can only be made after consideration of all relevant information, consultations and material considerations.</i>				
Background and Site description	The site looks to take access via the recently constructed public road.			
Assessment	I have no objections to this proposal provided conditions similar to the ones below are included in any consent given.			
Recommendation	<input type="checkbox"/> Object	<input type="checkbox"/> Do not object	<input checked="" type="checkbox"/> Do not object, subject to conditions	<input type="checkbox"/> Further information required
Recommended Conditions	<p>No development shall commence until a scheme of details has first been submitted to, and approved in writing by, the Planning Authority showing the precise details of the proposed access and visitor parking. Thereafter the approved scheme of details shall be fully implemented prior to the access hereby approved coming in to use, unless otherwise agreed in writing with the Council. Reason: To ensure the access is formed to an appropriate standard.</p> <p>Parking for two vehicles, excluding garages, must be provided within the curtilage of each plot before each dwellinghouse is occupied and retained thereafter in perpetuity. Reason: To ensure the development is served by adequate parking at all times.</p> <p>The visitor parking and access shown on drawing 10148_1_2 must be constructed as per an approved scheme prior to the dwellings being occupied and retained thereafter in perpetuity unless otherwise agreed in writing with the Council. Reason: To ensure development hereby approved is served by an appropriate level of parking.</p>			
Recommended Informatives	<p>All work within the public road boundary must be undertaken by a contractor first approved by the Council.</p> <p>The access to the site to be constructed to the following specification from the carriageway edge: 6 metres wide over the initial 6m with 8 metre radii and radius kerbing to match existing, incorporating a pedestrian crossing point, surfaced as follows: 40mm of 14mm size close graded bituminous surface course to BS 4987 laid on 60mm of 20mm size dense binder course (basecourse) to the same BS laid on 350mm of 100mm broken stone bottoming blinded with sub-base, type 1.</p>			

AJS